



शुद्धिपत्र/ Corrigendum No.1

Date: 11.02.2019

Please refer to Bank's Tender Ref. no. **314/2019/1426/HO1/PREMISES** dated **February 01st, 2019** "**HVAC Works including supply, installation, testing and commissioning etc. in SIDBI Head Office at SIDBI Tower 15, Ashok Marg, Lucknow**"

The following changes have been made in the Terms and Condition of the Tender through this Corrigendum.

S. No.	Reference	Clause as per tender	Revised clause	Comments
1	Volume II – Financial bid – S.no. 1.1 VRF/VRV outdoor	Supply of outdoor units equipped with highly efficient scroll compressor with inverter type compressor, special acrylic coated heat exchanger, low noise condenser fan, auto check function for connection error, MS stand , having interconnected control wiring between IDU ODU. Control panel and refrigerant piping housed in compact housing duly powder coated complete as required for trouble free operation, refrigerant should be R410A and as per specifications. Installation, testing and commissioning of Variable refrigerant flow/ Variable refrigerant volume type system with indoor units including individual controller for cooling and heating type operation.	Supply of outdoor units equipped with highly efficient scroll compressor with inverter type compressor, special acrylic coated heat exchanger, low noise condenser fan, auto check function for connection error, having interconnected control wiring between IDU ODU. Control panel and refrigerant piping housed in compact housing duly powder coated complete as required for trouble free operation, refrigerant should be R410A and as per specifications. Installation, testing and commissioning of Variable refrigerant flow/ Variable refrigerant volume type	Rate for MS stand to be quoted in Item no. 5 of Financial bid. Hence, the mention of MS stand mentioned in S.no. 1.1, BOQ description stands omitted.

S. No.	Reference	Clause as per tender	Revised clause	Comments
		The quoted price should include all duties, insurance FOR site etc. as per specifications.	system with indoor units including individual controller for cooling and heating type operation. The quoted price should include all duties, insurance FOR site etc. as per specifications.	
2	Volume II – Financial bid – S.no. 1.2 Indoor Unit	Supply, installation testing and commissioning of indoor units equipped with pre-filter, fan section with low noise fan, multispeed motor, coil section with DX coil, outdoor cabinet, drain pan and drain pump, cordless remote/wire control for ductable, cabling, vibration isolation, earthing, necessary supports etc. as per specifications.	Supply, installation testing and commissioning of indoor units equipped with pre-filter, fan section with low noise fan, multispeed motor, coil section with DX coil, outdoor cabinet, drain pan and drain pump, cabling, vibration isolation, earthing, necessary supports etc. as per specifications.	Rate for corded Remote Controllers to be quoted in item no. 2. Hence, cordless remote/ wire control for ductable mentioned in S.no. 1.2, BOQ description stands omitted.
3	Volume II – Financial bid – S.no. 3	Supply, Installation, Testing & Commissioning of Refnets.	Supply, Installation, Testing & Commissioning of 3 no. Refnets.	Quantity shall be 3 nos. Rates to be quoted for the said quantity.
4	Volume II – Financial bid – S.no. 7	Supply, Fabrication, installation and testing of Al ducts in accordance with the approved shop drawings complete with all accessories like GI Flanges, suspension rods , anchor bolts, GI bolts & nuts etc.	Supply, Fabrication, installation and testing of GI ducts in accordance with the approved shop drawings complete with all accessories like GI Flanges, suspension rods , anchor bolts, GI bolts & nuts etc.	Al (Aluminium) ducts to be read as GI ducts. Ducts should be fabricated at site with good workmanship and the finished product should be of acceptable standard.

All other terms and conditions shall remain same as mentioned in our tender Tender Ref. no. **314/2019/1426/HO1/PREMISES** dated **February 01st, 2019**.

Kindly keep on checking our website www.sidbi.in regularly to get latest updates regarding this tender notice.

Bank reserves the right to change the dates, timings mentioned above or elsewhere mentioned in the RFP, which will be communicated by placing the same as corrigendum under Tender section on Bank's web-site.
